



### **List of Common School District Violations**

1. Corridors (means of egress during an emergency), or classrooms, cannot have more than 50% of the walls covered by decorations, or art work.
2. A minimum of 24" clearance must be maintained between the top of storage and the ceiling for buildings, without an automatic fire sprinkler. If a building has automatic sprinklers, the minimum clearance from the ceiling and storage is 18".
3. Storage of all combustible items must be orderly.
4. Aisle clearance must be at least 36" in all areas of the business accessible to the public. Non-public areas must be at least 24" wide.
5. Required exits shall not be locked or blocked. This includes the access leading to the exit.
6. Exit signs must be in operating condition and the battery back-up must work.
7. Extension cords should not be used in place of permanent wiring. U.L. listed power bars with a cord fewer than 12 feet in length will be allowed for computers and small devices.
8. All extinguishers must be serviced annually by a company licensed, by the Texas Commission on Fire Protection and must have a service tag attached.
9. All wiring shall comply with the national electrical code.
10. Post M.S.D.S. sheets for all chemicals in stock.
11. Maintain proper containment for hazardous materials.
12. Fire alarm annual inspection is required.
13. Sprinkler system annual inspection is required.
14. Updated keys, if changed, must be provided for the Key box
15. If faded and not legible, the fire lane must be restriped per WFR requirements.
16. Fire suppression system for vent-a-hoods must be inspected annually.
17. Proper containers and containment for combustible and flammable liquids must be maintained.
18. If in use, gas cylinders must be chained.
19. Gas cylinder storage area must be marked with signage.